

.

Temperature

RDM

Protocol Version	1.0
Device Model ID	307 (0x0133)
Supported Parameters	DMX_START_ADDRESS, SENSOR_DEFINITION, SENSOR_VALUE, DEVICE_LABEL, MANUFACTURER_LABEL, DEVICE_MODEL_DESCRIPTION
Sub Devices	6 (one per channel)

Lock

Reset

Set Up Parameter	State
Manual Control Levels	All Off
DMX Addresses	Block patch at 001
DMX Fail Mode	Hold Last State
Memory	All Memories Cleared
Sequence	All Sequences Cleared
Preheat	Off (0%) for all channels
Topset	100% for all channels
Law	Normal law for all channels
Switch law switch point	50% for all channels
RDM	Enabled

Firmware Version